

Annual Drinking Water Quality Report

Saratoga Springs City 2016

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources have been determined to be from ground water and surface water sources. Our water source comes from District Well 1, Well #2, Well #3, Well #4, and Well #6. We also purchase water from Central Utah WCD-Utah Valley.

The Drinking Water Source Protection Plan for Saratoga Springs is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources are located in remote and protected areas and have a low level of susceptibility to potential contamination sources. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

This report shows our water quality and what it means to you our customer.

If you have any questions about this report or concerning your water utility, please contact Matt Allinson at 801-766-9793. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Tuesdays of every month at 7:00 PM at the City Hall located at 1307 North Commerce Drive.

Saratoga Springs routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2016. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

ND/Low - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem outdated

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
Microbiological Contaminants							
Total Coliform Bacteria	N	1	N/A	0	5	2016	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N	0	N/A	0	None	2016	Human and animal fecal waste
Turbidity for Ground Water	N	0.02-2.7	NTU	0	0.3	2016	Soil runoff
Inorganic Contaminants							
Arsenic	N	1.6-3.3	ppb	0	10	2016	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	0.061-0.214	ppm	2	2	2016	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Carbon, Total Organic (TOC)	N	1.3-3.1	ppm	0	0	2015	Naturally present in the environment

Copper a. 90% results b. # of sites that exceed the AL	N	a.0.107 b.0	Ppm	1.3	AL=1.3	2015	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	0.2-0.3	ppm	4	4	2016	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. 1.4 b.	ppb	0	AL=15	2016	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	N	0-0.6	ppm	10	10	2016	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	0.08-5.4	ppb	50	50	2016	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	11.3-83.3	ppm	None set by EPA	None set by EPA	2016	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	8-153	ppm	1000	1000	2016	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved solids)	N	104-200	ppm	2000	2000	2016	Erosion of natural deposits
Disinfection By-products							
TTHM [Total trihalomethanes]	N	0-57.6	ppb	0	80	2016	By-product of drinking water disinfection
Haloacetic Acids	N	0-31.2	ppb	0	60	2016	By-product of drinking water disinfection
Bromate	N	0-30	ppb	0	10	2015	Water additive used to control microbes
Radioactive Contaminants							
Alpha emitters	N	1.1-4.6	pCi/l	0	15	2016	Erosion of natural deposits
Radium 228	N	0-1.2	pCi/l	0	5	2016	Erosion of natural deposits

We constantly monitor the water supply for various constituents. We have detected cryptosporidium in the Provo River Intake (from the water purchased from Central Utah WCD). We detected this constituent in 1 out of 1 samples tested. We believe it is important for you to know that cryptosporidium may cause serious illness in immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. These people should seek advice from their health care providers.

We are required to test our sources of drinking water, as well as our treated tap water, for the presence of Cryptosporidium. We test for this contaminant quarterly in both source water and treated water. Although small amounts were found in the source water, we did not find any in the treated water that goes to your tap. Cryptosporidium is a microbial parasite which is found

in surface water throughout the United States. Although Cryptosporidium can be removed by filtration, the most commonly used filtration methods cannot guarantee 100 percent removal. Our monitoring of source water and/or finished water indicates the presence of these organisms. Unfortunately, current test methods do not enable us to determine if the organisms are dead or if they are capable of causing disease. Symptoms of an infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals are able to overcome the disease within a few weeks. However, immunocompromised people have more difficulty and are at greater risk of developing severe, life-threatening illness. Immunocompromised individuals are encouraged to consult their doctor regarding appropriate precautions to take to prevent infection. Cryptosporidium must be ingested for it to cause disease, and it may be spread through means other than drinking water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Saratoga Springs City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or manmade. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at Saratoga Springs City work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.