

Saratoga Springs Fire & Rescue

HOME BUSINESS – SELF FIRE INSPECTION

This form is to be completed by the business owner. All of the information contained in this report is considered applicable unless otherwise specified. For questions please contact the fire department at 801-766-6505.

Business Name: _____

Business Address: _____

Business Owner: _____ Phone Number: _____

Check the most applicable answer to all questions:

<u>REQUIREMENTS</u>	<u>WHAT TO INSPECT</u>	<u>COMPLIANCE</u>
1. <u>Address</u>	Address numbers shall be a minimum of 4" in height and visible from the street.	YES <input type="radio"/> NO <input type="radio"/>
2. <u>Exits/Hallways</u>	Exit doors shall be operable and remain clear and free of obstructions: (Boxes, storage, deliveries, etc.)	YES <input type="radio"/> NO <input type="radio"/>
3. <u>Fire Extinguishers</u>	One 5lb commercial "2A10BC" rated, "serviceable type" extinguisher required. Mount in a readily accessible area of the home. Extinguisher is required to have an annual inspection and must be tagged by a certified service technician.	YES <input type="radio"/> NO <input type="radio"/>
4. <u>Storage</u>	Maintain 36" clearance around all electrical panels, furnace, water heater or any fuel-fired appliances.	YES <input type="radio"/> NO <input type="radio"/>
5. <u>Hazardous Materials</u>	Use or storage of flammable combustible liquids in large quantities? Use or storage of hazardous materials? (If answer to either of these questions is yes- a fire department inspection is required. Contact the fire department to schedule.	YES <input type="radio"/> NO <input type="radio"/>
6. <u>Electrical</u>	Extension cords cannot be used in place of permanent wiring. Small electrical appliances should be plugged into surge protectors. Power strips cannot be plugged into another power strip. No open slots in electrical panels allowed. All receptacles and switches shall have approved covers installed.	YES <input type="radio"/> NO <input type="radio"/>
7. <u>Smoke/CO Detectors</u>	At least one smoke detector is required on each level of the home. One CO detector or combination CO/smoke detector is required. Detectors should be tested monthly and batteries replaced annually.	YES <input type="radio"/> NO <input type="radio"/>
8. <u>Space Heaters</u>	Shall be UL listed and kept clear of all combustibles.	YES <input type="radio"/> NO <input type="radio"/>

I hereby certify that the information is true and correct to the best of my knowledge.

Business Owner _____ Signature _____ Date _____